

AUTHORIZATION TO DISCHARGE TO WATERS OF THE UNITED STATES,
NPDES PERMIT NO. NM0030503.

The applicant's mailing address is:

Village of Angel Fire
P.O. Box 610
Angel Fire, NM 87710

Under the Standard Industrial Classification (SIC) Code 4952, the applicant currently operates a publicly owned treatment works (POTW). The site is located at 67 Servises Road, Angel Fire, in Colfax County, New Mexico. The discharge is to Cieneguilla Creek, thence to Eagle Nest Lake, thence to the Cimarron River, thence to the Canadian River in the Water Quality Segment number 20.6.4.309 of the Canadian River Basin.

The treatment facility is a sequential batch reactor (SBR) system with ultra-violet (UV) disinfection. The facility has two lagoons that store wastewater prior to discharge either to the receiving stream or to a land application area. The facility has a design flow capacity of 0.50 million gallons per day (MGD). A statement of basis is available.

There are significant changes of permit conditions from the existing permit issued July 23, 2004, with an effective date of September 1, 2004, and an expiration date of July 31, 2007:

- (i) Add effluent limitations and monitoring requirements for E. coli;
- (ii) Delete effluent limitations and monitoring requirements for fecal coliform; and
- (iii) Change WET testing from 1/quarter to 1/year.